

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001


No. F.6/DFS/MS/School/2025/SZ/ 1139

Dated: 16 / 09 / 2025

FIRE SAFETY CERTIFICATE

Certified that the **Scholars Home International School** located at B-7/164, Phase-IV, Bandh Road, Aya Nagar Extension, New Delhi 110047 comprised of Ground plus Two Upper Floors owned/occupied by Scholars Home International School was issued FSC by this department vide letter no. F6/DFS/MS/School/2022/SZ/654 Dated 15/06/2022. The said premise was re-inspected by officer concerned of this department on 28/08/2025 in presence of Mrs. Chanchal (Principal) of the school and found that the said school building have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and the building is fit for occupancy class **"Educational Building Group - B" (for Ground plus two upper floor only)** with effect from 16/09/2025 for a period of **Three years** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of Delhi Fire Service Rules 2010.

Issued 16/09/2025 at New Delhi by



16/09/2025
(VIRENDRA SINGH)
CHIEF FIRE OFFICER
DELHI FIRE SERVICE

Copy to: -

1. The Principal, Scholars Home International School located at B-7/164, Phase-IV, Bandh Road, Aya Nagar Extension, New Delhi 110047
2. The Directorate of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi-54

Conditions for the validity of Fire Safety Certificate: -

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangement provided therein shall be maintained in good working condition at all time as seen during inspection. Any loss of life property due to non-functional fire safety measures shall be at the responsibility of the management.
3. All the staff members must know the correct method of operation of fire fighting system.
4. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
5. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or Alteration (Clause 1.4.3 of UBBL-2016), if any.
6. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in form 'J' [sub rule (I) of rule 37] along with a copy of this Certificate, six month prior to its expiry."
7. This FSC is valid for Ground and two upper floors only. The temporary rooms / structure at terrace shall not be used for any purposes. In case of any violation of this direction, Else otherwise, this FSC may be treated as null & void.


Principal
Scholars Home International School
B-7/164, Phase-IV, Bandh Road,
Aya Nagar Extension, New Delhi-110047